


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 21Date : 29-01-2025

It is certified that an inspection team headed by Dr. J. S. Dulera, Chief District Health Officer from DEPT. OF HEALTH, DIST. PANCHAYAT BHARUCH. inspected the RMPS INTERNATIONAL SCHOOL, 350/1, N.H. No. 8 At Andada, Ankleshwar, Dist. Bharuch - 393010, Gujarat. on 29-01-2025 and found that the RMPS INTERNATIONAL SCHOOL, 350/1, N.H. No. 8 At Andada, Ankleshwar, Dist. Bharuch - 393010, Gujarat. has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period upto. 31-12-2025



Chief District Health Officer

Signature with Seal : District Panchayat BharuchName: Dr. J. S. DuleraDesignation: CDHO

To,

Principal,

RMPS INTERNATIONAL SCHOOL350/1, N.H. No. 8 At Andada,Ankleshwar, Dist. Bharuch - 393010,Gujarat.



Taluka Laboratory, Ankleshwar
Gujarat Water Supply & Sewerage Board
Near Hast Talav, Opp Geeta R.O. Plant,
Navi Nagri Road, Ankleshwar-393001
Dist.-Bharuch



tlankleshwar@gmail.com

TL/7.8/F-01

તાલુકા પ્રયોગશાળા અંકલેશ્વર,
ગુ. પા. પુ. અને ગ.વ્ય. બોર્ડ, હસ્તી
તળાવ પાસે, ગીતા આ.રો પ્લાન્ટની
સામે, નવી નગરી રોડ,
અંકલેશ્વર-૩૯૩૦૦૧
જિ- ભરૂચ

Test Report

Name & Address of Customer:-

RMPS International School
350/1, B/H Akshar Icon,
Golden Bridge Road,
Andada, Ankleshwar

Customer Reference No. : Nil/dt.01/02/2025
Sample Submitted by : Senders
Date of Sample Receipt : 01/02/25
Analysis Starting Date : 03/02/25
Analysis completion Date : 03/02/25
ULR No : -
Discipline : Chemical Testing, Group: Water

Test Report No:	282/2024-25	Date of Issue :	04/02/25
Sample ID :	TACW-282/02-"25	Mode of Sample :	Satisfactory
Main Source :	R.O Water	Source :	-
Location :	At Sender Address		
Village :	Andada	Habitation :	Andada
Taluka :	Ankleshwar	District :	Bharuch
Latitude :	-	Longitude :	-

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

Sr. No.	Parameter	Unit	IS-10500:2012 (2nd Revision)		Reference Method :	Analytical Value
			Requirement (Acceptable Limit) Max.	Permissible Limit in the Absence of Alternate Source Max.		
1	Colour	Hazen	5	15	APHA (23 rd Ed.2017), Method: 2120 C	<1
2	Odour	-	Agreeable	Agreeable	IS 3025 (Part 5) - 2018 (Second Revision)	Agreeable
3	Taste	-	Agreeable	Agreeable	IS 3025 (Part 8) -1984 (Reaffirmed 2017)	Agreeable
4	Turbidity	NTU	1	5	APHA (23 rd Ed.2017), Method: 2130 B	0.54
5	pH at 25°C	-	6.5 to 8.5	No relaxation	APHA (23 rd Ed.2017) Method: 4500 H ⁺ B	7.36
6	Total Dissolved Solids	mg/l	500	2000	APHA (23 rd Ed.2017) Method: 2540 C	164
7	Total Hardness(as CaCO ₃)	mg/l	200	600	APHA (23 rd Ed.2017) Method: 2340 C	88
8	Calcium (as Ca ²⁺)	mg/l	75	200	APHA (23 rd Ed.2017) Method: 3500 Ca ²⁺ B	16
9	Magnesium (as Mg ²⁺)	mg/l	30	100	APHA (23 rd Ed.2017) Method: 3500-Mg ²⁺ B	17
10	Chloride (as Cl ⁻)	mg/l	250	1000	APHA (23 rd Ed.2017) Method: 4500-Cl ⁻ B	56
11	Sulphate (as SO ₄ ²⁻)	mg/l	200	400	APHA (23 rd Ed.2017) Method: 4500-SO ₄ ²⁻ E	1.53
12	Nitrate (as NO ₃ ⁻)	mg/l	45	No relaxation	APHA (23 rd Ed.2017) Method: 4500-NO ₃ ⁻ B	0.00
13	Fluoride (as F ⁻)	mg/l	1.00	1.50	APHA (23 rd Ed.2017) Method: 4500-F ⁻ C	0.06
14	Total Alkalinity (as CaCO ₃)	mg/l	200	600	APHA (23 rd Ed.2017) Method: 2320 B	88

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.

Name & Designation of Authorized Signatory

O.W.No. TLA/ 1019 /of 2025, Dt. 04/02/2025.

End of the Test Report

Taluka Laboratory Ankleshwar, At. Po. Ankleshwar, Dist. Bharuch



IS-10500:2012 (2nd Revision)

Sr. No.	Parameter	Unit	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
			Max.	Max.
1	Colour	Hazen	5	15
2	Odour	-	-	-
3	Taste	-	-	-
4	Turbidity	NTU	1	5
5	pH at 25 ⁰ C	-	6.5 to 8.5	No relaxation
6	Total Dissolved Solids	mg/l	500	2000
7	Total Hardness (as CaCO ₃)	mg/l	200	600
8	Calcium (as Ca)	mg/l	75	200
9	Magnesium (as Mg)	mg/l	30	100
10	Chloride (as Cl)	mg/l	250	1000
11	Sulphate (as SO ₄)	mg/l	200	400
12	Nitrate (as NO ₃)	mg/l	45	No relaxation
13	Fluoride (as F)	mg/l	1.00	1.50
14	Total Alkalinity (as CaCO ₃)	mg/l	200	600



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

RMPS International School
350/1, B/H Akshar Icon,
Golden Bridge Road, Andada, Ankleshwar

Sender's Ref. No. : Nil/dt.01/02/2025

Ref. Date : 01/02/2025

Date & Time of Commencing Examination : 01/02/2025

Sample collected by : Senders

BW No.	TABW 259
Date of Collection	01/02/2025
Date of Arrival at Lab.	01/02/2025
Source of Water Sample	R.O Water At Sender Address
Village	Andada
Habitation	Andada
Taluka	Ankleshwar
District	Bharuch
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C	A
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C
MPN of coliform per 100 ml of sample at 37° C	<2
MPN of Faecal coliform per 100 ml of sample at 44° C	<2
Free Chlorine (PPM)	Nil
OPINION FOR POTABILITY :	FIT

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than

NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.

@ All Water Intended for Drinking -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

@ Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

(b) Total coliform bacteria shall not be detectable in any 100ml sample.

@ 0.2ppm Free Residual Chlorine at consumer end is recommended.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24hrs.

Outward No.: BAR / 1020/ of 2025, Date: 04 / 02 / 2025 Authorised Signatory